

# RIVERSIDE PLUMBING COMPANY LTD.

8125 HWY 62 - RR # 1  
FOXBORO, ONTARIO KOK 2B0

613-966-1920

## WELL REPORT

DATE: MAR 22 2002

LOT: \_\_\_\_\_

NAME: DAVE ROBERTSON

CON: \_\_\_\_\_

CIVIC ADDRESS: 971 NAPHAN RD

R.R. #1, ROSLIN ONT KOK2Y0

TOWNSHIP: \_\_\_\_\_

DUG: \_\_\_\_\_

DEPTH OF WELL: 58 FEET

DRILLED: \_\_\_\_\_

CASING DIAMETER: 6 INCHES

STATIC LEVEL: 26 FEET

G.P.M. (10+) TEN PLUS

Well Technician Licence: T-0681

Technician: Rick Beaudrie

Signature: 

A WELL TEST IS ONLY ACCURATE ON THE DATE THE WELL IS TESTED



# The Ontario Water Resources Act WATER WELL RECORD

1. PRINT ONLY IN SPACES PROVIDED  
2. CHECK  CORRECT BOX WHERE APPLICABLE

11

2913496

MUNICIP.

29022

CON.

CON.

09

COUNTY OR DISTRICT <b>HASTINGS</b>	TOWNSHIP BOROUGH CITY, TOWN VILLAGE <b>TYENDINAGA</b>	CON. BLOCK, TRACT, SURVEY ETC <b>CONC. 9</b>	DATE COMPLETED DAY <b>22</b> NO <b>FEB</b> YEAR <b>90</b>
[REDACTED]		12 BLOOMFIELD CRT.	

## LOG OF OVERBURDEN AND BEDROCK MATERIALS (SEE INSTRUCTIONS)


GENERAL COLOUR	MOST COMMON MATERIAL	OTHER MATERIALS	GENERAL DESCRIPTION	DEPTH - FEET	
				FROM	TO
BROWN	SAND	GRAVEL	FROZEN	0	2
BROWN	SAND	STONES	DENSE	2	12
BROWN	SAND	BOULDERS	DENSE	12	15
GREY	LIMESTONE		HARD	15	55

31

32

<b>41 WATER RECORD</b> WATER FOUND AT - FEET: <b>50'</b> KIND OF WATER: <input checked="" type="checkbox"/> FRESH <input type="checkbox"/> SALTY <input type="checkbox"/> SULPHUR <input type="checkbox"/> MINERALS <input type="checkbox"/> GAS		<b>51 CASING &amp; OPEN HOLE RECORD</b> INSIDE DIAM. INCHES: <b>8</b> MATERIAL: <b>STEEL</b> WALL THICKNESS INCHES: <b>1.88</b> DEPTH - FEET: <b>0 21'</b> <b>67 208</b> <b>68</b> <b>21 55'</b>		<b>SCREEN</b> SIZE, I.D. OF OPENING (SLOT NO.): MATERIAL AND TYPE: DEPTH TO TOP OF SCREEN:	
<b>61 PLUGGING &amp; SEALING RECORD</b> DEPTH SET AT - FEET: MATERIAL AND TYPE (CEMENT GROUT LEAD PACKER ETC): <b>21 16</b> <b>16 0</b> <b>CEMENT GROUT</b> <b>SAND &amp; OVERBURDEN MATERIALS</b>					

<b>71 PUMPING TEST</b> PUMPING TEST METHOD: <input checked="" type="checkbox"/> PUMP <input type="checkbox"/> BAILER PUMPING RATE: <b>5</b> GPM DURATION OF PUMPING: <b>1</b> HOUR <b>20</b> MIN	WATER LEVEL END OF PUMPING: <b>29</b> FEET WATER LEVELS DURING PUMPING: 15 MINUTES: <b>50'</b> 30 MINUTES: <b>45</b> FEET 45 MINUTES: <b>45</b> FEET 1 HOUR: <b>50</b> FEET 1 1/2 HOURS: <b>50</b> FEET 2 HOURS: <b>50</b> FEET	
	PUMP INTAKE SET AT: <b>50'</b> FEET WATER AT END OF TEST: <b>10</b> FEET <input type="checkbox"/> CLEAR <input checked="" type="checkbox"/> CLOUDY	
	RECOMMENDED PUMP TYPE: <input checked="" type="checkbox"/> SHALLOW <input type="checkbox"/> DEEP RECOMMENDED PUMP SETTING: <b>50'</b> FEET RECOMMENDED PUMPING RATE: <b>10</b> GPM	



<b>FINAL STATUS OF WELL</b> <input checked="" type="checkbox"/> WATER SUPPLY <input type="checkbox"/> OBSERVATION WELL <input type="checkbox"/> TEST HOLE <input type="checkbox"/> RECHARGE WELL	<input type="checkbox"/> ABANDONED, INSUFFICIENT SUPPLY <input type="checkbox"/> ABANDONED, POOR QUALITY <input type="checkbox"/> UNFINISHED <input type="checkbox"/> DEWATERING
<b>METHOD OF CONSTRUCTION</b> <input checked="" type="checkbox"/> CABLE TOOL <input type="checkbox"/> ROTARY (CONVENTIONAL) <input type="checkbox"/> ROTARY (REVERSE) <input type="checkbox"/> ROTARY (AIR) <input type="checkbox"/> AIR PERCUSSION	<input type="checkbox"/> BORING <input type="checkbox"/> DIAMOND <input type="checkbox"/> JETTING <input type="checkbox"/> DRIVING <input type="checkbox"/> DIGGING <input type="checkbox"/> OTHER

<b>CONTRACTOR</b> NAME OF WELL CONTRACTOR: <b>PHILIP EDWARD MCKEE WELL CONTRACTORS</b> ADDRESS: <b>Box 3 Milford Ont</b> SIGNATURE OF CONTRACTOR: <b>Ross Branson</b>	WELL CONTRACTOR'S LICENCE NUMBER: <b>6005</b> WELL TECHNICIAN'S LICENCE NUMBER: <b>624</b>

<b>OFFICE USE ONLY</b> DATE OF INSPECTION: REMARKS:	CONTRACTOR: <b>6005</b>	DATE RECEIVED: <b>MAR 27 1990</b>
	SIGNATURE OF INSPECTOR: <b>CSS.ES</b>	