

HOME INSPECTION SERVICES

Residential • Commercial • Farm Properties

Septics • Wells & Potable Water • Consulting Services

homeinspection@nexicom.net

613-395-1100 Office

613-442-5332 Cell

Well Report

Date / Time Sept 12 / 23
Property Address 2988 Pine Grove Rd
Town/Prov/PC Scelys Bay ON 911 # 2988

Description of Well and Water Supply System
Drilled well with submersible pump

Depth of Well 200' +

Volume of Water in Well 184'

Static Level 16'

Pump Rate / 1 Minute 5 gpm

Pump Rate / 60 Minutes 300 gallon test


Well Recovery Rate / 1 Minute 4 gpm

This well report described above, located at the address on this form, covers the aforementioned water system at the time of this inspection. We will have no liability for any claim or complaint if conditions have been disturbed, altered, repaired, replaced or otherwise changed any time after this inspection.

Base Fee \$ 250.00
Tax GST \$ 32.50
Total Fee \$ 282.50

HST #82973 8616 RT0001

Inspector - **Bernie Hennessy License #12240**

Signed  Dated Sept 12/23