

Measurements recorded in: Metric Imperial

Tag#: A140329

Page _____ of _____

Address of Well Location (Street Number/Name) MAPLE LAWN R.O.			Township KINGSTON		Lot 33	Concession 5	
County/District/Municipality FRONTENAC			City/Town/Village KINGSTON		Province Ontario		Postal Code
UTM Coordinates	Zone	Easting	Northing		Municipal Plan and Sublot Number		Other
NAD	8	3	193831044906474		BLG LOT 1		

Overburden and Bedrock Materials/Abandonment Sealing Record (see instructions on the back of this form)					
General Colour	Most Common Material	Other Materials	General Description	Depth (m/ft)	
				From	To
BROWN	CLAY			0	23
BLUE	LIMESTONE			23	30
GREEN	LIMESTONE			30	39
GREY	SANDSTONE			39	65
RED	SANDSTONE			65	100

Annular Space			
Depth Set at (m/ft)		Type of Sealant Used (Material and Type)	Volume Placed (m³/ft³)
From	To		
26	0	CEMENT	10

Method of Construction		Well Use	
<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Diamond	<input type="checkbox"/> Public	<input type="checkbox"/> Commercial
<input type="checkbox"/> Rotary (Conventional)	<input type="checkbox"/> Jetting	<input checked="" type="checkbox"/> Domestic	<input type="checkbox"/> Municipal
<input type="checkbox"/> Rotary (Reverse)	<input type="checkbox"/> Driving	<input type="checkbox"/> Livestock	<input type="checkbox"/> Test Hole
<input type="checkbox"/> Boring	<input type="checkbox"/> Digging	<input type="checkbox"/> Irrigation	<input type="checkbox"/> Cooling & Air Conditioning
<input checked="" type="checkbox"/> Air percussion		<input type="checkbox"/> Industrial	
<input type="checkbox"/> Other, specify		<input type="checkbox"/> Other, specify	


Construction Record - Casing			Status of Well	
Inside Diameter (cm/in)	Open Hole OR Material (Galvanized, Fibreglass, Concrete, Plastic, Steel)	Wall Thickness (cm/in)	Depth (m/ft)	
			From	To
64"	STEEL	188	2	26
6"	OPEN HOLE		26	100

Construction Record - Screen				
Outside Diameter (cm/in)	Material (Plastic, Galvanized, Steel)	Slot No.	Depth (m/ft)	
			From	To

Water Details		Hole Diameter	
Water found at Depth (m/ft)	Kind of Water: <input type="checkbox"/> Fresh <input checked="" type="checkbox"/> Untested	Depth (m/ft)	Diameter (cm/in)
		From	To
63	<input type="checkbox"/> Gas <input type="checkbox"/> Other, specify	0	26 10"
90	<input type="checkbox"/> Gas <input type="checkbox"/> Other, specify	26	100 6"

Well Contractor and Well Technician Information			
Business Name of Well Contractor JACK KNOX WELDRILLING		Well Contractor's Licence No. 3202	
Business Address (Street Number/Name) 2580 PERTH R.O.		Municipality GLENBURNE	
Province ONT	Postal Code K0H1S0	Business E-mail Address	
Bus. Telephone No. (inc. area code) 6135466164		Name of Well Technician (Last Name, First Name) KNOX JOHN	
Well Technician's Licence No. 2879		Signature of Technician and/or Contractor <i>[Signature]</i>	

Results of Well Yield Testing				
After test of well yield, water was:	Draw Down		Recovery	
	Time (min)	Water Level (m/ft)	Time (min)	Water Level (m/ft)
<input checked="" type="checkbox"/> Clear and sand free				
<input type="checkbox"/> Other, specify				
If pumping discontinued, give reason:	Static Level	24.4		
Pump intake set at (m/ft) 98'	1	29.1	1	26.3
Pumping rate (l/min / GPM) 56 G.P.M.	2	29.2	2	25.5
Duration of pumping 1 hrs + 0 min	3	29.3	3	25.4
Final water level end of pumping (m/ft) 30.6	4	29.4	4	25.4
If flowing give rate (l/min / GPM)	5	29.5	5	25.4
Recommended pump depth (m/ft) 97	10	29.8	10	24.9
Recommended pump rate (l/min / GPM) 56 G.P.M.	15	30	15	24.4
Well production (l/min / GPM) 10 G.P.M.	20	30.2	20	"
Disinfected? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	25	30.3	25	"
	30	30.4	30	"
	40	30.4	40	"
	50	30.5	50	"
	60	30.6	60	"



Well owner's information package delivered <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Date Package Delivered 20130517	Ministry Use Only Audit No. Z161220 Received JUN 10 2013
Date Work Completed 20130517		