

Client Information

Name: _____

Address: _____

Phone: (H) _____ (W) _____

Well Location:

Address: 1023 NEVA LN.

SOUTH FRONTENAC

Well Tag: _____

GPS Coordinance: N _____ W _____

Inspection:

Good Fair Poor N/A

Pump ☒ ☐ ☐ ☐

Type SUBMERSABLE Voltage 230

Pressure Tank ☐ ☐ ☐ ☐

Type BLADDER Age + 5 YRS

Filtration ☐ ☐ ☐ ☒

Type _____

Ultra Violet ☐ Date of last service _____

Type _____

Good Fair Poor N/A

Well ☒ ☐ ☐ ☐

Type 6" DRILL Depth 90 ft.

Electrical ☒ ☐ ☐ ☐

Notes: _____

Vermin Proof Cap Yes/No

Notes: _____

Other _____

Water Analysis:

Hardness 18 grains

Iron 41 ppm

H²S 0 ppm

TDS 327 ppm

Ph 7

Chlorine 0 ppm

Other 0

Minutes	Pumping	Recovery	Rate (usgpm)
1	27.2	30.3	6.8
2	27.5	28.4	
3	28.0	28.0	
4	28.4	27.8	
5	28.7	27.5	
6	29.1	27.3	
7	29.5	27.0	
8	29.9	26.6	
9	30.3	25.4	
10	30.7	25.2	6.8
13	31.9	24.0	
15	32.8	23.5	
20	32.8	22.6	6.8
25	32.8	22.4	
30	32.8		
40	32.8		
50	32.9		
60	32.9		6.8

Notes and Recommendations

* GALV. FITTINGS AT PRESSURE TANK SHOULD BE REPLACED W/ STAINLESS OR BRASS

① WATER SOFTENER

② ULTRA VIOLET LIGHT.

Static 22.4 ft. Static at end of pumping 32.9 ft. Final recovery 22.4 ft. Total pumped 408 usgal.

The data in the attached table supports the conclusion that the well is producing 6.8⁺ usgal per minute.

I hereby certify that the data on this report is true and accurate to my knowledge at the time of testing.

Name: WILL HAMILTON

Signature: Will Hamilton

Date: JUNE 17, 2025

The pumping test has been done in accordance with the requirements in the Water Act and the Ground Water Protection Regulation. PLEASE NOTE: The data recorded in this pumping test report reflect conditions at the time of the test. Water levels, well performance, estimated long-term well yield and water quality are not guaranteed as they are influenced by a number of factors, including natural variability, human activities, and condition of the works, which may change over time.