Job #48574

Well & Pump Inspection

Licensed Well Technician performs a draw down and recovery test of well to provide a production (well yield) rate. Includes visual inspection of well and pump system and report. Well flow rates are subject to seasonal change.

Well Type

Identifies standard construction type.

Shore Well



Well Casing Diameter

Identifies standard casing diameters

36"

Well Casing Material

Identifies standard casing material.

Concrete

Static Water Level

Water level identified at start of testing. Measured from head of well to water level.

8.3’

Well Depth

Top of well head to bottom of well.

14’

Reserve / Capacity

Identified by gallons removed from draw down test or volume calculation of water column. Provides insight to water available on hand before production number is relevant.

Approx 300 gallons

Production Rate

5+ GPM

Well Notes

Well influenced by water level of bay. Could not pump static down.

Pump & Pressure System Notes

Single line jet pump system in good working order.



Additional Notes

No concerns the well and pump performance are meeting the needs of the home.